

**WARREN
EPSTEIN**
& Associates,
Architects, Inc.

Warren M. Epstein, AIA
Kyle F. Epstein, AIA
Milan M. Gross, AIA
Thomas E. Mottern, AIA

FAX COVER SHEET

ADDENDUM NO. 2

DATE: **11 May 2007**

TO: **All General Contractors**

FROM: **Tom Mottern**

RE: **Project No. J-112
Renovation and Addition to Callaway Building
University of West Georgia
Carrollton, Georgia**

NUMBER OF PAGES INCLUDING THIS COVER SHEET:

5

Addendum No. 2, dated 11 May 2007. Hard copy mailed this date.

1785 Cheshire Bridge Road, NE
Atlanta, Georgia 30324
Telephone 404.873.5111
FAX 404.873.5113

WARREN EPSTEIN & ASSOCIATES, ARCHITECTS, INC.
1785 Cheshire Bridge Road, N.E.
Atlanta, Georgia 30324

11 May 2007

ADDENDUM NO. 2 to the Drawings and Specifications entitled "Project No. J-112, Renovation and Addition to Callaway Building for University of West Georgia, Carrollton, Georgia", dated 2 April 2007.

The Addendum hereby becomes a part of the Contract Documents for the above named work and supersedes all provisions of the above referenced Drawings and Specifications in conflict herewith.

1. Reference is made to Addendum No. 1, dated 3 May 2007. Under Heading 14.C, change the word "Map" to "Mop".
2. Reference is made to "Section 071119 - Sheet Membrane Vapor Barrier" of the Specifications. Under Heading 2.1.A, add the following manufacturer:
 - "4. Stego Industries,"
3. Reference is made to "Section 076200 - Sheet Metal Flashing and Trim" of the Specifications. Under Heading 1.3.C, delete the Heading in its entirety and replace with the following:
 - "C. Samples for Initial Selection: Manufacturers' color charts or chips showing the full range of colors for each type of sheet metal flashing and trim."
4. Reference is made to "Section 096816 - Sheet Carpeting" of the Specifications. Under Heading 2.1.B.1.a, add the following manufacturer:
 - "7. Bigelow Commercial, The Mohawk Group."
5. Reference is made to "Section 115313 - Laboratory Fume Hoods" of the Specifications. Under Heading 2.1.A, add the following manufacturers:
 - "6. CampbellRhea, a Sagus International Company.
 7. Air Master Systems Corporation."
6. Reference is made to "Section 123553 - Laboratory Casework" of the Specifications. Under Heading 2.1.A.1, add the following manufacturers:
 - "d. CampbellRhea, a Sagus International Company.
 - e. Diversified Woodcrafts, Inc.
 - f. Air Master Systems Corporation."
7. Reference is made to "Section 126800 - Seminar Tables/Swivel Seating" of the Specifications.
 - a) Under Heading 2.1.A, add the following manufacturer:
 - "5. Irwin Seating Company, Edwin Copeland III, 770/461-2090."
 - b) Under Heading 2.5.G, delete Heading "G" in its entirety.
8. Reference is made to "Section 210001 - General Requirements (Fire Suppression)" of the Specifications.

Addendum No. 2
11 May 2007
Page Two

- a) Under Heading 1.4.B, delete the Heading in its entirety and replace with the following:
"B. See Articles 1.9 and 1.12 of the Supplementary General Conditions."
 - b) Under Heading 1.11.A, change "Article 1.11" to "Article 1.14".
 - c) Under Heading 1.19.A, change "Article 1.29" to "Article 1.32".
 - d) Under Heading 3.2.A, change "Article 1.28" to "Article 1.31".
9. Reference is made to "Section 220001 - General Requirements (Plumbing)" of the Specifications.
- a) Under Heading 1.4.B, delete the Heading in its entirety and replace with the following:
"B. See Articles 1.9 and 1.12 of the Supplementary General Conditions."
 - b) Under Heading 1.8.A, change "Article 1.4" to "Article 1.17".
 - c) Under Heading 1.12.A, change "Article 1.11" to "Article 1.14".
 - d) Under Heading 1.20.A, change "Article 1.29" to "Article 1.32".
 - e) Under Heading 3.2.A, change "Article 1.28" to "Article 1.31".
10. Reference is made to "Section 230001 - General Requirements (HVAC)" of the Specifications.
- a) Under Heading 1.4.B, delete the Heading in its entirety and replace with the following:
"B. See Articles 1.9 and 1.12 of the Supplementary General Conditions."
 - b) Under Heading 1.10.A, change "Article 1.11" to "Article 1.14".
 - c) Under Heading 1.18.A, change "Article 1.29" to "Article 1.32".
 - d) Under Heading 3.2.A, change "Article 1.28" to "Article 1.31".
11. Reference is made to "Section 230002 - Heating, Ventilating and Air Conditioning Equipment" of the Specifications.
- a. Under Heading 2.6.B, add the following manufacturer:
"Vibration Eliminators Company."
 - b. Under Heading 2.7.B, add the following manufacturer:
"Raywall."
 - c. Under Heading 2.13.B, add the following manufacturer:
"Nailor Industries, Inc."

Addendum No. 2
11 May 2007
Page Three

- d. Under Heading 2.15.A, add the following manufacturer:
"Raywall."
 - e. Under Heading 2.16.A, add the following manufacturer:
"Nailor Industries, Inc."
 - f. Under "Part 2 - Equipment", add the following new Heading:
"2.20 FUME HOOD EXHAUST FANS:"
 - A. Type: Centrifugal utility set.
 - B. Acceptable Manufacturers: Kewaunee, Peerless, American Blower, Penn.
 - C. Components: Single width, single inlet forward curved blade centrifugal blower with non-sparking wheel, explosion-proof motor and drive in rotatable weatherproof housing with mounting base.
 - D. Accessories: Discharge transition section and stainless steel exhaust stack.
 - E. General: Provide variable pitch motor sheave where belt drive is scheduled."
12. Reference is made to "Section 230004 - Sheet Metal Work, Ductwork & Vents (HVAC)" of the Specifications.
- a) Under Heading 2.1.F, add the following manufacturer:
"Arrow United Industries."
 - b) Under Heading 2.1, add the following new sub-heading "N":
"N. Exposed round low pressure supply ducts shall be spiral lock type."
13. Reference is made to "Section 230006 - Insulation (HVAC)" of the Specifications; Under Heading 2.1.E, add the following:
"Cover supply ductwork in Mechanical Penthouse with 2" thick rigid board insulation with appropriate finish jacket."
14. Reference is made to "Section 329200 - Turf and Grasses" of the Specifications. Under Heading 3.1, add the following new Heading "C":
"C. Turfgrass sod shall be installed at pervious areas inside the limits of construction and/or at existing turf areas damaged by construction work."
15. Reference is made to "Sheet AS-1.1" of the Drawings.
- a) At Detail "13/AS-1.1", change "4" concrete walkway" note to "8" concrete walkway."
 - b) At Detail "15/AS-1.1", delete "4" granular fill" from Detail.

Addendum No. 2
11 May 2007
Page Four

16. Reference is made to "Sheet AS-1.2" of the Drawings. Delete "4" granular fill" from the following Details:

"4/AS-1.2 at exterior of the building, 5/AS-1.3, 6/AS-1.2, 7/AS-1.2, 8/AS-1.2, 9/AS-1.2, 11/AS-1.2 and 12/AS-1.2"
17. Reference is made to "Sheet A-3.1" of the Drawings. Revise Detail "3/A-3.1" Window Type "E" as follows:
 - a) Move the arrow for "1" Insulated Glass" note to the bottom half of the window type.
 - b) The upper half of the window type shall be "Opaque Spandrel Glass."
18. Reference is made to "Sheet A-6.2" of the Drawings. Add the following note to Details "24/A-6.2", "25/A-6.2" and "26/A-2";

"Plastic Laminate on 3/4" Plywood, refer to Millwork Sections on this Sheet."
19. Reference is made to "Sheet M-1" of the Drawings. Under "Air Handling Unit Schedule", delete footnote 3.
20. Reference is made to "Sheet M-2" of the Drawings. Under "Pumps" Schedule, delete footnote 1 and replace with the following:
 - "1. Provide inertia base vibration isolation for all pumps."
21. Reference is made to "Sheet P-3" of the Drawings. Under "Plumbing Fixtures" Schedule, add the following manufacturers:
 - A. Under Lavatory P-2, add "Symmons S-20-0-IPS."
 - B. Under Lavatory P-2A, add "Symmons S-20-0-IPS."
 - C. Water Cooler P-4, add "Halsey Taylor HAC8FS-BL-Q-PV."
 - D. Shower Valve P-6, add "Symmons BP-56-300-B30-L-V-X."
22. Reference is made to "Sheet E-1.1" of the Drawings. Under "Site Plan Notes", add the following to Site Plan Note "5";

"Primary service shall consist of two 4" conduits with 250 KCM copper conductors. Encase in 3000 psi concrete duct bank. See Detail 6/E-4.1."