

ADDENDUM NO.1

DATE: April 6, 2007

PROJECT: FIRE STATION NO. 50
JACKSONVILLE, FL

TO: BEACH BOULEVARD VENTURE, LLC
12854 KENAN DRIVE, SUITE 100
JACKSONVILLE, FL 32258

FROM: PQH ARCHITECTS, INC
4141 SOUTHPOINT DRIVE EAST, SUITE 200
JACKSONVILLE, FL 32216

THIS ADDENDUM SHALL BE ATTACHED TO AND FORMS A PART OF THE PROJECT DOCUMENTS

SPECIFICATIONS:

1. TABLE OF CONTENTS: Replace this section with the attached.
2. Section 04700 MANUFACTURED MASONRY: Add this section in its entirety.
3. Section 08410 LARGE MISSILE IMPACT ALUMINUM ENTRANCES AND STOREFRONTS: Page 08410-5, Part 2.3, G, revise to read as: Color: Bone White.
4. Section 09510 ACOUSTICAL CEILINGS:
 - a. Page 09510-3, Part 2.2 A, revise to read as:
 - A. Type 1 (ACT) – Living Areas:
 1. Acoustical panels: ACT Design Basis: USG Interiors, Inc.
 - a. Eclipse ClimaPlus, Square Edge.
Size: 24” x 24” x 3/4”
Item No.: 76575
NRC: .70
Color: White
Mineral fiber substrate with washable vinyl surface.
 - b. Page 09510-3, Part 2.2, B, add the following:
 - B. Type 2 (ACT) – Apparatus Bay 116, Laundry 119 and Bunker Gear 126:
 1. Acoustical panels: ACT Design Basis: USG Interiors, Inc.
 - a. Sheetrock Branch Lay-in Ceiling Panel; ClimaPlus with vinyl face, Square Edge.
Size: 24” x 24” x 1/2”

Item No.: 3260

Color: White

- c. Page 09510-3, Part 2.2, C, revise to read as: ...DXT – W/ Type 1 ACT
 - d. Page 09510-3, Part 2.2, C, delete “Nominal Width”
 - e. Page 09510-4, Part 2.2, C, revise to read as: ...ZCLA W/ Type 2 ACT
- 5. Section 09680 CARPET: Add this section attached in its entirety.
 - 6. Section 09900 PAINTING: Add this section attached in its entirety.
 - 7. Section 11400 STAINLESS STEEL COUNTERTOPS: Add this section attached in its entirety.
 - 8. Section 015600 HEATING, VENTILATION AND AIR CONDITIONING: Revise the footer spec number to read as: 15600.

CHANGES TO THE DRAWINGS:

- 1. Sheet I-2:
 - a. Updated the wind loads reference to ASCE 7-02
 - b. Revised F. Components and Cladding to read as: 1. Shall be designed by a professional engineer licensed in the state of Florida or have a Florida Product Approval #.
- 2. Sheet A-1:
 - a. Added (2) 2A-10BC fire extinguishers on hooks in Apparatus Bay and (1) 2A-10BC in recessed cabinet at end wall of pantry cabinets in Kitchen/Dining.
 - b. Changed symbol for Kitchen fire extinguisher.
- 3. Sheet A-3 and A-4: Added height above finished floor for cultured stone base.
- 4. Sheet A-7: Detail 11 modified to show detail with stucco trim water table with dimensions to indicate size.
- 5. Sheet A-9:
 - a. Revised wall finish for the restrooms to indicate epoxy paint on walls for Toilet 104, Restroom 115A and Baths 121 and 124.
 - b. Added remarks to see specs for ACT Type I and ACT Type 2.
 - c. Changed fixed glass to “single hung” for window Types A and C.
- 6. Sheet A-10:
 - a. Revised ceiling material to ACT 2 (Type 2) for spaces 118, 125 and 126.
 - b. Legend modified the description for the 2x2 material acoustical tile to include “Type 1 and 2 (see spec revision). Type 1 U.O.N.
 - c. Added Type 2 to Reflected Ceiling Plan for the Apparatus Bay 118, Laundry 125 and Bunker Gear 126.
- 7. Sheet A-11: Details 3, 14, 15 and 15.1: Deleted the tile wainscot and/or added note for epoxy paint.

8. Sheet E-3: Removed indication for washer extractor and disconnect switch for laundry 125.
9. Sheet E-4: Removed washer extractor for panel P.2.

ATTACHMENTS:

Specifications: TOC, 04700, 9680, 09900 and 11400

Drawings: (8 ½ x 11) I-2, A-3, A-7 and A-11 (2)

Drawings: A-1 and A-10

END OF ADDENDUM NO. 1