

This Addendum is hereby made a part of the Contract Documents on the subject work as though originally included therein. The following clarifications, amendments, additions, deletions and/or modifications to the Specifications and Drawings change the original documents only in the manner and the extent stated.

PART I - PERTAINING TO THE DRAWINGS:

IA. Sheet AC103:

Change Typical Perimeter Elevation for low-slope roofs from of 8 or 9 inches indicated to "10 inches".

PART II - PERTAINING TO THE PROJECT MANUAL:

IIA. Section 001116 - Invitation to Bid:

1. Change date of bid from "Thursday, 5 April 2007" to "Tuesday, 10 April 2007".

END OF ADDENDUM ONE