



SKINNER VIGNOLA & McLEAN, INC.

ARCHITECTS & PLANNERS

1628 N.W. 6TH STREET

GAINESVILLE, FLORIDA 32609

FL CERT. #AA3478

(352) 378-4400

(FAX) 377-5378

Renovations to the Putnam County Governmental Complex Bid # 07-14

00505

May 09, 2007

ADDENDUM #3

This Addendum is for the information of the Contractor and shall become part of the Contract Documents. This Addendum contains the following:

1. These two (2) pages.
2. Fire Wall Detail
3. Roof Plans A1.3, A2.3, A3.3, A4.3, A5.3, A6.3 & A7.3, rev 05/07/07.
4. Revised Partial 1st Floor Plan
5. Steps & Ramp Sections
6. CMU Opening Reinforcing & Infill Details.
7. Interior Elevations at N128, N101, N135, O106 & O126.

GENERAL

- 3.1 Fire Wall Construction: See attached Detail for roof and front walkway construction at the tenant walls separating spaces L & M and M & N. Also reference attached Roof Plans.
- 3-2. Roof Scuttles: Install at the rear of Suite N with wall-mounted access ladder. See A3.3
- 3-3. Sidewalks: New sidewalks shall be limited to areas designated on Sheet SP-3 & SP-4. All existing sidewalks under the existing canopies shall be painted with equivalent to Sherwin-Williams Floor & Porch Enamel. See Section 09905 for preparation requirements.
- 3.4 Proposed Openings/Infill in CMU Wall: See attached CMU opening reinforcing and infill details.
- 3-5. Handrails, Stairs & Ramps: Reference attached step & ramp sections for construction of such at Suite P, O, and N. Also reference Specification Section 02444, and Details 7, 9 & 15/S1.02
- 3-6. Tipping Fees: The contractor shall be responsible for including the costs for the disposal of demolished material

SPECIFICATIONS

- 3-7. 06410 PLASTIC LAMINATE CABINETRY
- 3-8. 10535 ALUMINUM CANOPIES: Correction: Finish shall be factory enameled finish, not anodized.

DRAWINGS

- 3-9. Drawing Sheet SP-5, Section A: Correction: Wall shall be 8" CMU centered on 12"x12" piers.
- 3-10. Drawing Sheet SP-5, Section C: Provide 6" concrete slab at bottom of fountain with #3



SKINNER VIGNOLA & McLEAN, INC.

ARCHITECTS & PLANNERS

1628 N.W. 6TH STREET
GAINESVILLE, FLORIDA 32609
FL CERT. #AA3478

(352) 378-4400
(FAX) 377-5378

horizontal reinforcing at 12" o.c. each way.

- 3-11. Drawing Sheet A0.0: Disregard all structural notes.
- 3-12. Drawing Sheet A1.2: Modification - see partial revised plan of commissioner's offices. Modifications include the cabinetry and the addition of door at the end of the hall.
- 3-13. Reference attached sheet A2.3, "Building O Roof Plan," which was inadvertently deleted from the original Bid Set. Replace A1.3, A3.3, A4.3, A5.3, A6.3 & A7.3 with the attached Roof Plans with revision date 05/07/07.
- 3-14. Reference Sheet A2.5: The correct scale for elevations 1, 2, 3 & 10 is 1/4" = 1'-0".
- 3-15. Cabinetry Drawings : Clarification - see attached interior elevations for cabinetry in spaces N128, N100, N101, N135, O106 & O126. See elevation 7/A3.5 for cabinetry in N117; see elevation 12/A2.5.1 for cabinetry in N120; see 7/A6.5 for cabinetry in D103 (not C101).
- 3-16. Structural Drawings: Clarification: "Structural Sheathing" shall refer to ½" oriented strand board.

END OF ADDENDUM NO. 3

The Contractor shall acknowledge receipt of this Addendum on the face of their bid.

Sincerely,

SKINNER VIGNOLA McLEAN, INC.

Howard J McLean, Jr., AIA
Lic. #AR14129

cc: Bidders & Plan Rooms, Owner, Consultants, Office File & Stick Set