

Southern A&E, LLC
 7951 Troon Circle
 Austell, Georgia 30168
 (770)-819-7777



Project Name: Addition to Villa Rica High School
 Project Number: 01-601-126
 Client: Carroll County Schools
 City/State: Carrollton, Georgia

Addendum Date: June 5, 2007
 Bid Date: June 21, 2007

Post-it® Fax Note	7571	Date	6/5/07	# of Pages	1
To	Dean Holders	From	Dean		
Co. Dept.	of Record	Co.	Holdinger		
Phone #		Phone #			
Fax #		Fax #			

TO REGISTERED HOLDERS OF BID DOCUMENTS

~~INFORMATION CONTAINED IN THIS ADDENDUM SUPERSEDES PREVIOUS INFORMATION CONTAINED IN BID DOCUMENTS~~

INFORMATION CONTAINED IN THIS ADDENDUM SUPERSEDES PREVIOUS INFORMATION CONTAINED IN BID DOCUMENTS

CHANGES TO SPECIFICATIONS

1. Section 00930 - Advertisement for Bids
 - a. The bid date has been changed to June 21, 2007 at 2:00 pm.
2. Section 10100 - Visual Display Boards
 - a. Add Education Essentials/ School Specialty as an approved manufacturer to paragraph 2.1.A.
3. Section 12343 - Wood Laboratory Casework
 - a. Change paragraph 2.4.A.4 to the following:
 4. Drawer/ Door fronts: 3/4-inch plywood or solid hardwood of the flush overlay type with a 3mm hardwood edge band to match.
 - b. Change paragraph 2.6.B to the following:
 - B. Hinges: Brushed Aluminum, 5-knuckle hinges complying with BHMA 156.9, Grade 1, with anti-friction bearings and rounded tips. Provide 2 for doors less than 48 inches high and 3 for doors more than 48 inches high.
 - c. Change paragraph 2.7.C.4.a to the following:
 - a. Top Configuration: Square edge with drip groove and 4" applied backsplash.

END OF ADDENDUM NO. 2
 01-601-126